

PLANTA
ESC-125


Technical drawing of a square box with a circular lid. The drawing includes the following dimensions and features:


- Overall width: 2.40
- Inner width: 2.00
- Height: 2.00
- Lid diameter: TAMPÃO Ø 900 mm
- Offset dimensions: 0.45 (indicated on the left and bottom)
- Section lines: A-A (horizontal) and B-B (vertical)

Technical drawing showing a cross-section (Corte A-A) of a vertical manhole assembly. The drawing includes the following components and dimensions:

- Top Cover:** TAMPÃO Ø900mm (8).
- Internal Components:**
 - 1: Flange/Support Ring
 - 2: Gasket/Seal
 - 3: Valve/Accessories
- Dimensions:**
 - Overall height: 2.80
 - Internal diameter: Ø500mm - F.F"
 - Offset from bottom: 0.40
 - Bottom layer thickness: 0.05
 - Bottom layer thickness: 0.05
- Structural Layers (Bottom):**
 - LASTRO DE CONCRETO MAGRO
 - LASTRO DE BRITA
 - ENCHIMENTO
 - SOLO COMPACTADO
- Labels:**
 - BLOCO DE APOIO
 - NF
 - Z
 - NT
 - GI

CAIXA DE VENTOSA	ESTACA	NT	Z	NF	GI	PROF.
2	70+0,00	598,000	598,000	595,200	595,600	2,80



Nº	DATA	REVISÃO	EXECUTADO POR	APROVADO POR	SEMAE		DESENHOS DE REFERÊNCIA	NÚMERO	NOTAS	SEMAE VISTO E ACEITO	EXECUTADO POR:	Serviço Municipal de Água e Esgoto de Piracicaba PROJETO BÁSICO DA ADUTORA DE ÁGUA TRATADA CAPIIM FINO - TORRE DE TV		N.o	
					ACEITO	DATA									REV.
										ESTA ACITAÇÃO NÃO ISENTA A CONTRATADA DAS RESPONSABILIDADES E OBRIGAÇÕES ESTABELECIDAS NO CONTRATO.	DES.: E.A.V.	07/2019		0	01/01
										ANALISADO: / /	PROJ.: A.F.R.F.	07/2019			N.º CONTRATADA
										ACEITO: / /	APROVADO POR: V.O.M.				389-HID-ADU02-009
										VISTO: / /	ASS: CREA: 0600490805	07/2019			ESCALA
												ÁREA PROJ.: MUNICÍPIO DE PIRACICABA			INDICADA
												SUB-ÁREA PROJ.: SISTEMA DE ABASTECIMENTO DE ÁGUA			